
	<b>GREATER HYDERABAD MUNICIPAL CORPORATION FIRE PREVENTION WING NO OBJECTION CERTIFICATE</b>		
NOC Number :	<b>00144/OFNOC/EDN/2018/WZ</b>		
Date of NOC:	<b>12/APR/2018</b>		
Valid upto:	<b>12-04-2023</b>		
NOC Type:	<b>OCCUPANCY*</b>		
Applicant Details:	<b>RAVELLY VENU GOPAL, 9346783450, sy.no:501 SPRING LEAF APARTMENTS</b>		
Building Address for which NOC issued:	<b>Delhi Public School , SURVEY NO. 74, KHAJAGUDA VILLAGE</b>		
Plot Area (in Sq. Mtrs.)	<b>19151.48</b>	Height (in Metres) : <b>13.70</b>	
Open Spaces (in Metres):	North : (F) <b>7.00</b>	South : <b>10.00</b>	East : <b>6.00</b> West : <b>6.00</b>
No. of Floors: 0 Sub-Cellar, 0 Cellar, 1 Ground/Stilts, 3 floor(s)	Occupancy Type: <b>Educational</b>		
Total Built-up Area (in Sq.Mtrs) : <b>2013.36</b>	Staircases	No. of Staircases Required/Proposed : <b>3.00</b>	
Fees Paid (in Rs.) : <b>20133.60</b>		Aggregate Width Required/Proposed (in Metres) : <b>4.00</b>	
Entry and Exit Gates (in Metres):	Entry Gate : <b>4.50</b>	Exit Gate : <b>4.50</b>	
<b>Minimum Fire Fighting Installations Provided as per Table-7, Part-IV of NBC, 2016:</b>			
Sl.No.	Particulars of fire fighting installations	Quantity	
1	Fire Extinguishers	10	
2	First Aid Hose Reel	8	
3	Down Comer	0	
4	Automatic Sprinkler System	0	
5	Manually Operated Electric Fire Alarm Systems	1	
6	Fire pump of 450 LPM at the terrace tank level with minimum pressure of 3.5 Kg / cm <sup>2</sup> (450 LPM extra when basement area exceeds 200 m <sup>2</sup> )	1	
7	Terrace tank 10000 Ltrs (5000 ltrs extra when basement area exceeds 200 m <sup>2</sup> )	10000	
<b>The No Objection Certificate for Occupancy is issued subject to following conditions:</b>			
a. The applicant should follow the Serial No. 1, 4 of Form No.18 [See Rule 15(1) (f)] of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006.			
b. In pursuance of the orders of the Hon'ble High Court mentioned at Sl.No. 1 of Form No.18 and on the basis of the recommendations of the building inspection committee, this No Objection Certificate for Occupancy is issued.			
c. Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.			
d. The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During			



the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.

e. It is the responsibility of the builder/management to apply for Renewal of No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.

f. The floor wise built-up areas of the building are as follows:

S.No.	Floor Type	Area in Sq. Mts.	Type of Occupancy	No. of People/Students
1	Ground/Stilt	503.34	PARKING	0
2	I Floor	503.34	ADMIN OFFICE	25
3	II Floor	503.34	CLASS ROOMS	100
4	III Floor	503.34	CLASS ROOMS	100



**DR.B. JANARDHAN REDDY, I.A.S.,**  
**Commissioner**  
**GHMC ,Hyderabad.**

**Note: This certificate is digitally signed by the Authority Competent To Grant License and can be verified online on <http://www.ghmc.gov.in>**

Print

Back